



Corrigendum to EN 50130-4:1995/A2:2003

English version

---

*Add:*

### **5.3 Operating condition**

**Replace** the first paragraph with the following:

Where a relevant European product performance standard (EN) exists, which defines suitable operating condition(s) during environmental or EMC tests (e.g. EN 54 series for fire alarm systems, EN 50131 series for intruder alarm systems), the operating condition(s) of the EUT, during the test conditions, shall be as defined in that standard.

### Clause 6

*Modify the instruction to read:*

**Replace** the first indent with the following:

---

March 2003